

SENSEI Plus Storage flow rates

N1300i						
Number of water heaters	Plus 300 (300 litre vessel)			Plus 500 (500 litre vessel)		
	1st Hour	Continuous	Storage Recovery Time	1st Hour	Continuous	Storage Recovery Time
	50°C ΔT		Minutes	50°C ΔT		Minutes
1	1073	773	24	-	-	-
2	1847	1546	12	-	-	-
3	2620	2319	8	-	-	-
4	-	-	-	3593	3092	10
5	-	-	-	4366	3865	8

SENSEI Plus Storage flow rates

N1600i						
Number of water heaters	Plus 300 (300 litre vessel)			Plus 500 (500 litre vessel)		
	1st Hour	Continuous	Storage Recovery Time	1st Hour	Continuous	Storage Recovery Time
	50°C ΔT		Minutes	50°C ΔT		Minutes
1	1254	954	19	-	-	-
2	2208	1908	10	-	-	-
3	3162	2862	7	-	-	-
4	-	-	-	4316	3816	8
5	-	-	-	5270	4770	7

Infinity VCM Plus storage flow rates

HD55i						
Number of water heaters	Plus 300 (300 litre vessel)			Plus 500 (500 litre vessel)		
	1st Hour	Continuous	Storage Recovery Time	1st Hour	Continuous	Storage Recovery Time
	50°C ΔT		Minutes	50°C ΔT		Minutes
1	1133	833	22	-	-	-
2	1966	1666	11	-	-	-
3	2799	2499	8	-	-	-
4	-	-	-	3832	3332	9
5	-	-	-	4665	4165	8

Note: All recovery times have been rounded up to the nearest minute.

Individual unit performance charts

ΔT°C	N1300i		N1600i		HD55	
	L/MIN	L/HOUR	L/MIN	L/HOUR	L/MIN	L/HOUR
25	25.8	1547	31.8	1907	27.8	1667
30	21.5	1289	26.5	1589	23.2	1389
35	18.4	1105	22.7	1362	19.8	1191
40	16.1	967	19.9	1192	17.4	1042
45	14.3	859	17.7	1060	15.4	926
50	12.9	773	15.9	954	13.9	833
55	11.7	703	14.4	867	12.6	758
60	10.7	644	13.2	795	11.6	695
65	9.9	595	12.2	734	10.7	641
70	9.2	552	11.4	681	9.9	595
75	8.6	516	10.6	636	8.7	521

